



- Notes:**
- This drawing is ©. All rights reserved.
 - Do not scale from this drawing. Only for illustration purposes.
 - Specify any specific requirements prior to ordering. All civil works by customer.
 - Observe all safety regulations in regard to excavation and lifting requirements. Never leave opening uncovered or unattended at any time.
 - Must be placed on a level base.

Minimum separation details
EPA 2009 CoP Table 6.1

	Tanks	Percolation
Water Course	10m	10m
Well	10m	15-60m
Lake	50m	50m
Boundary	3m	3m
Road	4m	4m
House	7m	10m

MOLLOY
ENVIRONMENTAL SYSTEMS
Clara Rd., Tullamore, Co. Offaly
T: 057 9326000 E: info@mollyprecast.com
F: 057 9326060 W: www.mollyprecast.com

QUALITY ISO 9001:2015 NSAI Certified
ENVIRONMENTAL MANAGEMENT ISO 14001:2015 NSAI Certified
HEALTH & SAFETY OHSAS 18001:2014 NSAI Certified
CIRI 2018/2019
ENGINEERS IRELAND REGISTERED PROFESSIONAL ENGINEER 2018

Title: 8PE Chlehtaln coconut filter with 110mm outlet

PE: 8 PE

Drg. no.: Coco_8PE_01_211119

Date: 21/11/2019

Drawn by: SF Checked by: KR